



U.S. Department of Transportation
Pipeline and Hazardous Materials
Safety Administration



Regulatory Next Steps in Addressing Pipeline Seam Weld Challenges

**2014 KCC Kansas Pipeline Safety Seminar
October 28th & 29th**





Regulatory Next Steps in Addressing Pipeline Seam Weld Challenges

- **Introduction and History**
- **Regulatory Mandate and Recommendations**
- **Seam Study – Phase 1**
- **Seam Study – Phase 2**
- **Integrity Verification Process – Overview**
- **Regulatory Action – Status Update**



Introduction and History

- **U.S. PHMSA - Advisory Bulletins on ERW Seam Failures**
 - **Alert Notice – ALN-88-01 and ALN-89-01**
 - Advised operators and the public on factors contributing to operational failures of pipelines constructed prior to 1970 with Electric Resistance Weld (ERW) seams
- **Liquid Propane Pipeline Rupture – Carmichael, MS**
 - November 1, 2007
 - Fracture along LF-ERW seam
 - 2 fatalities and 7 injuries

**Incident #1 -
Carmichael, MS**






Introduction and History

- **Natural Gas Transmission Rupture – San Bruno, CA**
 - September 9, 2010
 - Failure of 30-inch diameter weld seams
 - Fracture along partial welded seam – 6 short pipe joints
 - 5 pups fabricated in 1956, did not meet pipe quality standards
 - 8 fatalities, many injured, 38 homes destroyed, 70 homes damaged

Incident #2 San Bruno, CA



Photograph of the 28-foot-long ruptured section of pipeline



U.S. Regulatory Mandate and Recommendations: *Pipeline Safety Act of 2011*

- **Pipeline Safety Act of 2011 - Section 23**
- **Verification of Records and Reporting**
 - Identify pipe segments with no records to verify Maximum Allowable Operating Pressure (MAOP) for all Gas Transmission steel pipe [Class 3, 4 and all High Consequence Areas (HCAs)]
- **Determination of MAOP**
 - Reconfirm MAOP for pipeline segments with insufficient records
- **Testing Regulations**
 - Requires conducting tests to confirm material strength of previously untested gas transmission steel pipelines in HCAs and operating pressure of +30% Specified Minimum Yield Strength (SMYS) that were not previously pressure tested



U. S. Regulatory Mandate and Recommendations: *NTSB Recommendations*

- **NTSB P-09-01 "Comprehensive Study"** – to identify actions that can be implemented to eliminate catastrophic longitudinal seam failures in ERW pipe
- **NTSB P-09-02 "Implement Actions from Study Findings"**
- **NTSB P-11-14 "Delete Grandfather Clause"** – recommends all grandfathered pipe be pressured tested, including a "spike" test
- **NTSB P-11-15 "Seam Stability"** – recommends pressure test to $1.25 \times \text{MAOP}$ before treating latent manufacturing and construction defects as "stable"
- **NTSB P-11-17 "Piggable Lines"** – Configure all lines to accommodate smart pigs, with priority given to older lines



U. S. Regulatory Mandate and Recommendations

- **How much pipeline mileage will these mandates and recommendations effect?**



Piggability: ILI Able vs Not Able

Part R	Total Miles	ILI Able	ILI Not Able
Class 1 - HCA	1,658	1,380	278
- non-HCA	234,851	146,035	88,816
Class 2 - HCA	1,409	1,152	257
- non-HCA	28,978	15,073	13,905
Class 3- HCA	15,850	10,469	5,381
- non-HCA	16,751	6,924	9,827
Class 4 - HCA	752	366	386
- non-HCA	209	112	97
TOTAL	300,458	181,511	118,947

Gas Transmission 2012 Annual Report data as of 7-1-2013



Summary of Gas Transmission (GT) Pipe

Location	Total GT Miles	% in HCA	GT HCA Miles	Non-HCA Miles
Class 1	237,756	0.7	1,660	236,096
Class 2	30,210	4.7	1,412	28,798
Class 3	32,613	48.6	15,854	16,759
Class 4	962	78.2	752	209
Total	301,540		19,678	281,862

Data as of 7-1-2013 from Part Q of Operator Annual Reports



Aging Infrastructure: % by Decade in USA


Decade	Hazardous Liquid	Gas Transmission	Gas Distribution Main	Service
Unknown & <1920	2%	---	---	---
1920s	2%	2%	---	---
1930s	3%	4%	6%	3%
1940s	8%	7%	2%	2%
1950s	20%	22%	10%	8%
1960s	21%	23%	17%	13%
1970s	16%	11%	12%	14%
1980s	9%	10%	14%	17%
1990s	11%	11%	21%	22%
2000s	8%	10%	18%	21%

Summary of Aging Infrastructure by Decade:

- Hazardous Liquid:** 56% (1920s-1950s), 44% (1960s-1990s)
- Gas Transmission:** 58% (1920s-1950s), 42% (1960s-1990s)
- Gas Distribution Main:** 47% (1920s-1950s), 53% (1960s-1990s)
- Service:** 40% (1920s-1950s), 60% (1960s-1990s)



Nominal Pipe Size





Pressure Test Range

Pressure Test Range	Total Miles	% Total
PT < 1.1 MAOP or no PT	93,817	31%
1.25 MAOP > PT ≥ 1.1 MAOP	19,131	6%
PT ≥ 1.25 MAOP	187,628	62%

Gas Transmission 2012 Operator Annual Report data as-of 7-1-2013



Seam Study

Comprehensive Study to Understand Longitudinal ERW Seam Failures

- **Research Contractor: Phase 1**
 - Battelle
- **Subcontractors: Phase 1**
 - Det Norske Veritas (DNV) & Kiefner and Associates (KAI)
- **Principle Investigators: Phase 1**
 - Bruce Young – Battelle
 - Brian Leis & Bruce Nestleroth, in conjunction with
 - John Kiefner (KAI) & John Beavers (DNV)
- **Phase 1 Completed – Jan. 2014; Phase 2 underway**



Phase 1 – Findings

- **ILI Detection & Sizing:**
 - ILI results show inconsistencies with digs & hydro test results
 - May be due to either ILI tool findings or interpretation
 - ILI tools are useful for finding & eliminating some seam defects
- **In-the-Ditch Assessment Methods**
 - No consistent standard practice
 - Can be inspector dependent
- **In-the-Ditch / ILI Improvements required for:**
 - More specific identification of anomaly type
 - Reduction of false calls
 - Improved sizing of defect depth and length for effective assessment and evaluation results



Phase 1 – Findings

- **Failure Pressure Models**
 - Should use a more representative Charpy impact toughness position relative to the bond line
 - Toughness values when unknown, need to be conservative
- **Predictive Model for Assessing Failure Stress Levels**
 - Must be based upon whether the failure is brittle or ductile, if unknown evaluate for both
 - Must use lower-bound failure stress levels based upon defect type (cold weld, hook cracks, stress corrosion cracking, etc.)



Phase 1 – Findings

- **Hydrostatic test pressures**
 - Need to be higher to be effective based upon a review of over 600 seam failures
 - Time to failure increases at an exponential rate to increased test pressure
 - Higher test pressures should mean longer interval before a retest



Phase 2 – Overview

- 1. Improve hydrotesting protocols for ERW/FW Seams**
- 2. Enhance Defect Detection and Sizing via Inspection**
- 3. Defect Characterization: Types, Sizes, & Shapes**
- 4. Develop & Refine Predictive Models & Quantify Growth Mechanisms**
- 5. Develop Management Tools**
- 6. Public Meeting/Forum**

Completed reports for Phase 1 available at:

<https://primis.phmsa.dot.gov/matrix/PrjHome.rdm?prj=390>



Integrity Verification Process (IVP)

Overview of Basic Principles



Principle #1

Apply to Higher Risk Locations

- **High Consequence Areas (HCAs)**
- **Moderate Consequence Area (MCA):**
 - Onshore area within a potential impact circle
 - Containing one or more buildings intended for human occupancy
 - Occupied site or designated Federal interstate, expressway, or 4-lane highway right-of-way
 - Does not meet definition of high consequence area, as defined in § 192.903.
- **PHMSA Estimates**
 - ~ 76,000 miles HCA/MCA (out of ~ 301,000 miles)



Principle #2

Screen for Categories of Concern

- **Apply process to pipeline segments with:**
 - Grandfathered Pipe
 - Lack of Records to Substantiate MAOP
 - Lack of Adequate Pressure Test
 - Operating pressures over 72% SMYS (pre-Code)
 - History of Failures Attributable to Manufacturing & Construction Defects



Principle #3

Know & Document Pipe Material

- **Inadequate Validated, Non-traceable Material Documentation, Establish Material Properties by an approved process:**
 - Cut out and Test Pipe Samples (Code approved process)
 - *In Situ* Non-Destructive Testing (if validated and if Code approved)
 - Field verification of code stamp for components such as valves, flanges, and fabrications
 - Other verifications




Principle #4

Assessments to Establish MAOP

- Allow Operator to Select Best Option to Establish MAOP
- **Candidate IVP Options for Establishing MAOP**
 - Subpart J Pressure Test with Spike Test
 - Derate Operating Pressure
 - Engineering Critical Assessment
 - Replace Pipe Segment
 - Alternative Technology or Technical Options
 - **Other options PHMSA should consider?**

Integrity Verification Process (IVP) Chart

- **Applicable Segments**
 - (Steps 1, 2, 3 and 4)
- **MAOP Determination Methods (Steps 5 – 10)**
 - Pressure Test
 - Pressure Reduction
 - Engineering Critical Assessment (ECA)
 - Pipe Replacement
 - Pressure Reduction for Segments w/Small PIR
 - Alternative Technology
- **Materials Documentation (11)**
 - Destructive
 - Non-destructive
- **Continue Operations (12)**




<http://primis.phmsa.dot.gov/meetings/MtgHome.mtg?mtg=91>



Why are pipeline material records needed?

- To establish design and MAOP
- For integrity management (IM)
- Anomaly evaluations for safe operating pressure
- Record Types:
 - Materials
 - Design
 - Construction
 - Pressure Testing
 - Corrosion Control
 - O & M –
 - IM, Surveys, Patrols, Manuals, Procedures



Metallurgical and Pipe Test Report

SAW PIPES USA, INC.
P.O. Box 2349
Bismarck, ND 58103-02349
Phone: (701) 339-3300
Fax: (701) 339-3371

WTR No: 480020362-4822
Sample No: J08206474

PO Number: 480020362 PO Date: 11/04/08 Date: 08/15/08
Diameter (in): 42 Wall (in): 0.438 Grade: X70 PS2 Heat No: 504628
Comments: LSAW MATERIAL AS-ROLLED 100% Wall exam required for ultrasonic testing without
Customer: CENTERPOINT ENERGY GAS TRANSMISSION COMPANY Calibration standard: 10 notches and 1/8" through drilled hole
Ship To: CENTERPOINT ENERGY GAS TRANSMISSION COMPANY
P.O. BOX 1314 LOUISIANA ARMY NATIONAL GUARD CAMP MINDEN 70508
MINOT, ND 58701

Physical Analysis:

Width	Yield	Tensile	Elong	Y/T	Ratio	Weld	Tensile	Fracture	Location
(in)	(ksi)	(ksi)	(%)				(ksi)		
1.5	55	65	25	0.85		OK	65		Face
1.4	55	65	25	0.85		OK	65		OK

Hydrostatic Test:

HYDRO PSI	HYDRO TIME (sec)
1400	20

MINIMUM HYDROSTATIC PRESSURE FOR THIS HEAT IS 1400 PSI @ 90%
NACRO OK

Chemical Analysis:

Type	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Ti	Al	N	S	Nb	Cu	Zr	CE	Pcm	V
Asm	0.09	1.50	0.006	0.005	0.27	0.02	0.02	0.18	0.01	0.010	0.007	0.007	0.001	0.0009	0.004	0.002	0.000	0.30	0.10
Prod	0.09	1.53	0.007	0.007	0.28	0.01	0.01	0.19	0.01	0.017	0.008	0.004	0.001	0.0009	0.002	0.002	0.000	0.30	0.10
Prod	0.09	1.53	0.006	0.005	0.28	0.01	0.01	0.18	0.01	0.017	0.008	0.004	0.001	0.0009	0.002	0.002	0.000	0.30	0.10

CE MAX = 0.41% PCM MAX = 0.21%

Hardness Analysis:

Temp	Shear	Shear	Shear	Avg
(°F)	(%)	(%)	(%)	(%)
32 F	100	97	99	

Charpy Impact Analysis:

Dirkloch	Spec Size	Temp	Flt 1b1	Flt 1b2	Flt 1b3	Flt 1b avg	Shear1	Shear2	Shear3	Shear Avg
							(%)	(%)	(%)	(%)
TBC	10x10 mm	32 F	128	133	173	145	100	100	100	100
THC	10x10 mm	32 F	110	115	112	112	100	100	100	100
TWC	10x10 mm	32 F	89	91	85	85	100	100	100	100

Fracture Toughness Criteria: As per API 5L, PSL2, SMA @ 50 F, S003 @ 50 F, S003 @ 50 F

The material has been manufactured, sampled, tested, and reported in accordance with the specification and has been found to meet the requirements. The results of the tests are as shown in the report of the company.



Material Documentation Plan

- **Procedures**

- Tests for:
 - Yield strength, ultimate tensile strength, seam type, coating type and chemistry
- Destructive Tests
 - Pipe removed from replacements and relocations
- Destructive and/or Non-Destructive Tests
 - Direct examinations, repairs, remediation & maintenance
- Tests used only to verify and document material grade



MAOP Determination

- **Applicable Locations**

- Located in HCA, MCA, and meets any of the following:
 - Experienced reportable in-service incident since last pressure test due...
 - Legacy pipe or constructed with legacy construction techniques and has not had a Pressure Test (PT) of the greater of
 - 1.25 times MAOP or applicable Class location PT requirement
 - No PT records
 - MAOP established per Grandfather Clause



MAOP Determination

- **Pressure Test**
 - 1.25 or class location test factor times MAOP
 - **Spike test segments** w/ reportable in-service incident due to legacy pipe/construction and cracking
 - Estimate remaining life, segments w/crack defects
- **Pressure Reduction**
 - Reduce pressure by MAOP divided by class location test factor
 - Estimate remaining life, segments w/crack defects
- **Pipe Replacement**
 - Install new pipe that meets Code requirements



MAOP Determination

- **Engineering Critical Assessment (ECA)**
 - ECA analysis – for MAOP
 - Segment specific technical and material documentation issues
 - Analyze crack, metal loss, and interacting defects remaining in pipe, or could remain in the pipe, to determine MAOP
 - MAOP established
- **Alternative Technology**
 - Alternative technical evaluation process that provides a sound engineering basis for establishing MAOP



Regulatory Action – Status Update

- **Notice of Proposed Rulemaking (NPRM)**
 - Regulation drafted
 - Being routed for approval to notice to Public
- **Applicable to Gas Transmission Pipelines**
 - 49 Code of Federal Regulations Part 192



Regulatory Next Steps in Addressing Pipeline Seam Weld Challenges

Stay Tuned

